

BRUHAT BENGALURU MAHANAGARA PALIKE

O/o Medical Officer of Health, 14th floor, PU building, MG Road, Bangalore-560001.

No: MOH/SHN/PR/347/2023-24

Date: 16/03/2024

NO OBJECTION CERTIFICATE

Subject: Regarding issue of No objection certificate to Good Shepherd School for the year 2024-25.

Reference: Request letter from the Good Shepherd School (Good Shepherd Convent) dated: 28/02/2024.

As per above mentioned subject and reference, **Good Shepherd School**, No 25, Museum Road, Ashok Nagar, Bangalore-560025 have submitted request letter for the issue no objection certificate for the year 2024-25. As per the request, Senior Health Inspector (Ward-111) has inspected the above mentioned institution and found that the School and campus has safe health and hygiene facilities for the students and staff members as per the norms prescribed by the Central/State/UT Government. The school management has paid the prescribed Government fees of Rs.4,000/- by DD with number 340183 Dated:28/02/2024 (Receipt No.000019). Hence No Objection certificate is issued for the financial year 2024-25 (till 31/03/2025) abided by the following terms and conditions.


Terms and Conditions:

1. RO Drinking water facilities are provided in each floor.
2. Separate clean toilet facilities for boys and girls are provided in each floor and maintained regularly.
3. The toilets are provided with proper water facilities.
4. The entire premises are kept in a neat and hygienic condition.
5. Tobacco products should not be sold in surrounding premises of the school/college premises.
6. Banned plastic should not be used in the premises.
7. Wet and dry wastes should be segregated and disposed scientifically as per SWM rules.
8. Necessary NOCs should be taken from the respective departments.
9. This certificate will be withdrawn at any point of time, if the above mentioned conditions are not being followed or any complaints received.


Medical Officer of Health
Shanthinagara Division
Bruhat Bengaluru Mahanagara Palike

To:

The Principal,
Good Shepherd School(Good Shepherd Convent),
No 25, Museum Road, Ashok Nagar,
Bangalore-560025.



KARNATAKA TEST HOUSE PVT. LTD.

MATERIAL TESTING LABORATORY

NABL Accredited Laboratory ISO/IEC 17025-2017



Report No.: KTH/WT/1745-2462/2023-2024
ULR No.: TC60112400000510F

Date: 11.03.2024.

TEST REPORT

Name of the Customer : M/s. GOOD SHEPERD SCHOOL.
Good Sheperd Convent, # 25, Museum Road,
Bangalore – 560 025.

Source of Sample : Supplied by the Customer.

Nature of Sample* : Water Testing for Drinking Purpose.

Sample Identification* : 'GOOD SHEPERD SCHOOL' Drinking Water.

Customer Reference : Letter dtd 04.03.2024

Sample Received on : 04.03.2024.

Duration of Test : 05.03.2024 to 11.03.2024

Description: - Colorless, odorless, transparent liquid.

Sl. No.	TESTS	UNITS	RESULTS	Maximum Acceptable Limits (mg/L)	Maximum Permissible Limits (mg/L)	Test Method
				(As per IS 10500:2012)		
1.	Colour	Hazen	<5	5	15	IS 3025 P (4) 2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 P (5) 2018
3.	Turbidity	NTU	<0.1	1	5	IS 3025 P (10) 2022
4.	pH Value @ 24.4 ° C	-	6.59	6.5 – 8.5	No Relaxation	IS 3025 P (11) 2017
5.	Electrical Conductivity	µS/cm	76.3	-	-	IS 3025 P (14) 2019
6.	Total Hardness as CaCO ₃	mg/L	15.5	200	600	APHA 24 th Edition 2340 C
7.	Calcium as Ca	mg/L	3.1	75	200	APHA 24 th Edition 3500 Ca B
8.	Magnesium as Mg	mg/L	1.8	30	100	APHA 24 th Edition 4500 B B
9.	Chloride as Cl	mg/L	9.5	250	1000	IS 3025 P (32) 2019
10.	Total Dissolved solids	mg/L	52.0	500	2000	IS 3025 P (23) 2019
11.	Sulphate as SO ₄	mg/L	<1.0	200	400	IS 3025 P (24) 2022
12.	Nitrate as NO ₃	mg/L	<1.0	45	No Relaxation	IS 3025 P (34) 2019
13.	Fluoride as F	mg/L	<0.1	1.0	1.5	APHA 24 th Edition 4500 F D
14.	Iron as Fe	mg/L	<0.1	1.0	No Relaxation	IS 3025 P (53) 2019
15.	Residual Free Chlorine	mg/L	<0.2	0.2	1	IS 3025 P (26) 2021
16.	Total Alkalinity as CaCO ₃	mg/L	19.5	200	600	IS 3025 P (23) 2019
17.	Aluminium as Al	mg/L	<0.05	0.03	0.2	APHA 24 th Edition 3500 Al B
18.	Boron as B	mg/L	<0.1	0.5	1.0	APHA 24 th Edition 4500 B B


* As furnished by the Customer.

Note: 1) This report is not to be reproduced except in full without our prior permission in writing.

2) The results listed refer only to the tested samples and applicable parameters.

3) Sampling not done by us.

778/44, Gokul 1st Stage, 2nd Phase, 8th Cross, Triveni Road, Yeshwanthpur, Bangalore - 560 054
Tele : 23378383 , 23375326 E-mail : kthblr@gmail.com Website : www.karnatakatesthouse.com



KARNATAKA TEST HOUSE PVT. LTD.

MATERIAL TESTING LABORATORY

778/44, Gokul 1st Stage, 2nd Phase, 8th Cross, Triveni Road,
Yeshwanthpur, Bangalore - 560 054. Tele : 23378383, 23375326
E-mail : kthblr@gmail.com Webstie : www.karnatakatesthouse.com

Report No.: KTH/WT/1745-2462/2023-2024

Date: 11.03.2024.


Sl. No.	TESTS	Unit	RESULTS	Maximum Acceptable Limits (mg/L)	Maximum Permissible Limits (mg/L)	Test Method
				(As per IS 10500:2012)		
19.	#E. Coli	Present/ Absent /100ml	Absent	Absent		IS 15185 2002
20.	#Total Coliform	Present/ Absent /100ml	Absent	Not Specified		IS 15185 2002

* As furnished by the Customer.

Indicates that these biological paramaters are got done through external agency.

Remarks: The given sample **conforms** to maximum acceptable limits of IS 10500: 2012 specifications.

For KARNATAKA TEST HOUSE PVT.LTD.



Review and Approved By
(MANJULA R)
TECHNICAL MANAGER



End of the report

Page 2 of 2

Note: 1) This report is not to be reproduced except in full without our prior permission in writing.
2) The results listed refer only to the tested samples and applicable parameters.
3) Sampling not done by us.